



FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Garibaldi Secondary	With Flush	NURSE OFFICE 2205	0.0021	No	
Garibaldi Secondary	Static	2210	0.0046	No	
Garibaldi Secondary	With Flush	2210	0.00057	No	
Maple Ridge Secondary	Static	O/S 1221	0.0057	Yes	2-minute flush
Maple Ridge Secondary	With Flush	O/S 1221	0.00062	No	
Maple Ridge Secondary	Static	CHANGE RM 1210	0.00086	No	
Maple Ridge Secondary	With Flush	CHANGE RM 1210	0.0079	Yes	2-minute flush
Maple Ridge Secondary	Static	O/S 1036	0.00018	No	
Maple Ridge Secondary	With Flush	O/S 1036	0.00024	No	
Maple Ridge Secondary	Static	CLASSROOM 122	0.00021	No	
Maple Ridge Secondary	With Flush	CLASSROOM 122	0.0017	No	
Maple Ridge Secondary	Static	1220	0.0027	No	
Maple Ridge Secondary	With Flush	1220	0.0011	No	
Maple Ridge Secondary	Static	O/S 2113	0.00013	No	
Maple Ridge Secondary	With Flush	O/S 2113	0.00009	No	
Maple Ridge Secondary	Static	O/S 2017	0.0016	No	
Maple Ridge Secondary	With Flush	O/S 2017	0.00031	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-1	0.00036	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-1	0.00031	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-2	0.00048	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-2	0.00012	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-3	0.00082	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-3	0.00039	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-4	0.00079	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-4	0.00041	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-5	0.00066	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-5	0.00043	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-6	0.00047	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-6	0.00036	No	
Maple Ridge Secondary	Static	CLASSROOM 1043-7	0.00047	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1043-7	0.00036	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-1	0.00053	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-1	0.00024	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-2	0.00054	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-2	0.00021	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-3	0.00068	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-3	0.00023	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-4	0.0041	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-4	0.00043	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-5	0.00062	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-5	0.00026	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-6	0.00026	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-6	0.00044	No	
Maple Ridge Secondary	Static	CLASSROOM 1044-7	0.00046	No	
Maple Ridge Secondary	With Flush	CLASSROOM 1044-7	0.00035	No	
Maple Ridge Secondary	Static	TEACH KIT 1037-1	0.00016	No	











FACILITY NAME	SAMPLE TYPE	LOCATION	RESULT (mg/L)	EXCEEDS	REMEDIATION
Golden Ears Elementary	With Flush	FOOD 1017	0.0004	No	
Hammond Elementary	Static	STAFF 2002	0.0011	No	
Hammond Elementary	With Flush	STAFF 2002	0.00044	No	
Hammond Elementary	Static	CLASSROOM 1019	0.0012	No	
Hammond Elementary	With Flush	CLASSROOM 1019	0.00033	No	
Hammond Elementary	Static	CLASSROOM 1017	0.00068	No	
Hammond Elementary	With Flush	CLASSROOM 1017	0.0004	No	
Hammond Elementary	Static	CLASSROOM 1015	0.00083	No	
Hammond Elementary	With Flush	CLASSROOM 1015	0.0018	No	
Hammond Elementary	Static	CLASSROOM 1015	0.00083	No	
Hammond Elementary	With Flush	CLASSROOM 1015	0.00062	No	
Hammond Elementary	Static	CLASSROOM 1013	0.0018	No	
Hammond Elementary	With Flush	CLASSROOM 1013	0.00058	No	
Hammond Elementary	Static	CLASSROOMN1016	0.0036	No	
Hammond Elementary	With Flush	CLASSROOMN1016	0.0011	No	
Hammond Elementary	Static	CLASSROOM 1006	0.00039	No	
Hammond Elementary	With Flush	CLASSROOM 1006	0.00039	No	
Hammond Elementary	Static	CLASSROOM 1043	0.00021	No	
Hammond Elementary	With Flush	CLASSROOM 1043	0.00054	No	
Harry Hooge Elementary	Static	NURSE 1005	0.00057	No	
Harry Hooge Elementary	With Flush	NURSE 1005	0.00016	No	
Harry Hooge Elementary	Static	CLASSROOM 1024	0.00059	No	
Harry Hooge Elementary	With Flush	CLASSROOM 1024	0.0013	No	
Harry Hooge Elementary	Static	O/S 1071	0.00018	No	
Harry Hooge Elementary	With Flush	O/S 1071	0.00021	No	
Harry Hooge Elementary	Static	FOOD 1056	0.003	No	
Harry Hooge Elementary	With Flush	FOOD 1056	0.00024	No	
Harry Hooge Elementary	Static	NURSE 1041	0.0081	Yes	2-minute flush
Harry Hooge Elementary	With Flush	NURSE 1041	0.00047	No	
Harry Hooge Elementary	Static	1042	0.0011	No	
Harry Hooge Elementary	With Flush	1042	0.00019	No	
Highland Park Elementary	Static	FOOD CW	0.00064	No	
Highland Park Elementary	With Flush	FOOD CW	0.00067	No	
Highland Park Elementary	Static	STAFF 1005C	0.00069	No	
Highland Park Elementary	With Flush	STAFF 1005C	0.00062	No	
Highland Park Elementary	Static	O/S 1012	0.002	No	
Highland Park Elementary	With Flush	O/S 1012	0.0014	No	
Kanaka Creek Elementary	Static	MULTI-PRP 1034	0.005	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	MULTI-PRP 1034	0.0037	No	
Kanaka Creek Elementary	Static	KITCHEN 1031	0.011	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	KITCHEN 1031	0.00038	No	
Kanaka Creek Elementary	Static	CLASSROOM 1021	0.005	Yes	2-minute flush
Kanaka Creek Elementary	With Flush	CLASSROOM 1021	0.00057	No	
Kanaka Creek Elementary	Static	STAFF 1008	0.0018	No	
Kanaka Creek Elementary	With Flush	STAFF 1008	0.00024	No	
Laityview Elementary	Static	O/S 1035	0.00023	No	

[Blue Header Bar]					

[Green Bar]

[Green Bar]

[Green Bar]

[Green Bar]

[Green Bar]